

Big Mesa Water Report

Month	Billed Gallons	HAA5*	TTHM*	Microbiological Sample
Dec-24	390,900	29.4	76.5	Absent
Jan-25	445,830	29.4	76.5	Absent
Feb-25	591,623	22	81.1	Absent
Mar-25	505,525	15	72.2	Absent
Apr-25	742,079	15	72.2	Absent
May-25	1,110,500	6.55	54.8	Absent
Jun-25	1,209,838	12.7	75.7	Absent
Jul-25	1,561,617	12.7	75.7	Absent
Aug-25	1,732,132	5.37	71.7	Absent
Sep-25	1,054,393	0	67.6	Absent
Oct-25	828,860	0	67.6	Absent
Nov-25	548,410	10	75.2	Absent
Dec-25	384,594	28	80.9	Absent

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.