

Big Mesa Water Report

Month	Billed Gallons	HAA5*	TTHM*	Microbiological Sample
Feb-23	562,690	7.54	66.9	Absent
Mar-23	508,810	20.7	88	Absent
Apr-23	866,020	20.7	88	Absent
May-23	996,963	11.3	92.7	Absent
Jun-23	902,603	6.27	79.2	Absent
Jul-23	1,649,491	6.27	79.2	Absent
Aug-23	1,413,994	5.65	48	Absent
Sep-23	1,226,716	3.51	50.4	Absent
Oct-23	773,538	3.51	50.4	Absent
Nov-23	441,620	7.67	54	Absent
Dec-23	368,350	42.5	87.3	Absent
Jan-24	466,250	42.5	87.3	Absent
Feb-24	638,348	12.6	94.8	Absent
Mar-24	461,179	27.5	119	Absent

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.