

## Big Mesa Water Report

<b>Month</b>	<b>Billed Gallons</b>	<b>HAA5*</b>	<b>TTHM*</b>	<b>Microbiological Sample</b>
May-21	964,170	7.83	63.6	Absent
Jun-21	1,752,740	9.63	52.3	Absent
Jul-21	1,473,520	6.38	65.8	Absent
Aug-21	1,731,430	N/A	N/A	Absent
Sep-21	1,758,613	9.9	58.6	Absent
Oct-21	814,240	N/A	N/A	Absent
Nov-21	834,204	6.93	59.5	Absent
Dec-21	399,710	8.96	65.7	Absent
Jan-22	747,700	8.86	66	Absent
Feb-22	721,329	8.86	66	Absent
Mar-22	631,030	17.1	74.6	Absent
Apr-22	847,350	17.1	74.6	Absent
May-22	1,640,838	7.48	77.1	Absent
Jun-22	1,548,443	12.1	<b>54.3</b>	Absent

\*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.