

Big Mesa Water Report

| Month | Billed Gallons | HAA5* | TTHM* | Microbiological Sample |
|--------|----------------|-------|-------|------------------------|
| Jul-22 | 1,562,830 | 12.1 | 54.3 | Absent |
| Aug-22 | 1,134,430 | 8.04 | 69.8 | Absent |
| Sep-22 | 1,189,440 | 8.04 | 69.8 | Absent |
| Oct-22 | 707,993 | 10.8 | 70.7 | Absent |
| Nov-22 | 519,570 | 6.59 | 71.8 | Absent |
| Dec-22 | 592,268 | 11.5 | 58.4 | Absent |
| Jan-23 | 510,908 | 11.5 | 58.4 | Absent |
| Feb-23 | 562,690 | 7.54 | 66.9 | Absent |
| Mar-23 | 508,810 | 20.7 | 88 | Absent |
| Apr-23 | 866,020 | 20.7 | 88 | Absent |
| May-23 | 996,963 | 11.3 | 92.7 | Absent |
| Jun-23 | 902,603 | 6.27 | 79.2 | Absent |
| Jul-23 | 1,649,491 | 6.27 | 79.2 | Absent |
| Aug-23 | 1,413,994 | 5.65 | 48 | Absent |

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.