

Big Mesa Water Report

Month	Billed Gallons	HAA5*	TTHM*	Microbiological Sample
Jun-25	1,209,838	12.7	75.7	Absent
Jul-25	1,561,617	12.7	75.7	Absent
Aug-25	1,732,132	5.37	71.7	Absent
Sep-25	1,054,393	0	67.6	Absent
Oct-25	828,860	0	67.6	Absent
Nov-25	548,410	10	75.2	Absent
Dec-25	384,594	28	80.9	Absent
Jan-26	538,048	28	80.9	Absent
Feb-26	726,375	14.2	76.2	Absent
Mar-26	831,390	0	86.1	Absent
Apr-26	1,274,688	0	86.1	Absent
May-26	1,251,463	12.1	54.3	Absent
Jun-26	1,615,392	0	67	Absent

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.