

Big Mesa Water Report

Month	Billed Gallons	HAA5*	TTHM*	Microbiological Sample
Apr-24	761,635	27.5	119	Absent
May-24	1,244,068	8.45	51.2	Absent
Jun-24	1,286,388	3.38	39.4	Absent
Jul-24	1,346,327	3.38	39.4	Absent
Aug-24	1,643,933	7.42	60.4	Absent
Sep-24	1,431,864	13.4	64	Absent
Oct-24	869,486	13.4	64	Absent
Nov-24	430,541	6.7	50	Absent
Dec-24	390,900	29.4	76.5	Absent
Jan-25	445,830	29.4	76.5	Absent
Feb-25	445,830	22	81.1	Absent
Mar-25	591,623	22	81.1	Absent
Apr-25	505,525	15	72.2	Absent

*Note: maximum contaminant level (MCL) for both Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) is 60 and 80, respectfully. These tests are performed quarterly.